

# CLASSIFICATION OF PROPERTIES

## MLTB-2284-2017-I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **P.P.H.U "ALFA" Sp. z o.o.**  
ul. Charnowo 3A, 76-270 Ustka

Product: double leaf window made of PVC profiles of system

### KÖMMERLING 76

Test results are included in the following test reports registered under the number of the request MLTB-2284-2017




Test methods:

Air permeability  
PN-EN 1026

Waterproofness  
PN-EN 1027

Wind load resistance  
PN-EN 12211

Security equipment capacity  
PN-EN 14609

Classification standards	PN-EN 12207	PN-EN 12208	PN-EN 12210	Threshold value
Product type (B x H mm)  1499 x 1499	<b>4</b>	<b>9A</b>	<b>C5</b>	<b>350 N</b>
Notes: Enveloped hardware Siegenia.				

### Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by *Head of Laboratory Mścichowski Adam*
- 2) tests made by *older technician Domański Adam*  
*assistant technician Grzyb Adam*

26-01-2017, Wałbrzych

**MOBILNE**  
Laboratorium Techniki Budowlanej Sp. z o.o.  
58-300 Wałbrzych, ul. Jana Kasprówicza 21 lok. 2  
tel. + 48 74 840 14 63, fax + 48 74 661 41 40  
NIP 8862868350, Regon: 020573602  
KRS: 0000461727

Term of control test within the FPC (ZKP): 26-01-2018

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprówicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
<http://www.badaniaokien.pl>  
e-mail: [biuro@badaniaokien.pl](mailto:biuro@badaniaokien.pl)

Notyfikowana jednostka  
(notified body) NB 2189